

DMR Copy of Record

Permit			
Permit #:	MA0003425	Permittee:	GLOBAL COMPANIES LLC
Major:	No	Permittee Address:	800 SOUTH STREET SUITE 500 WALTHAM, MA 02454
Permitted Feature:	001 External Outfall	Discharge:	001-A MONTHLY MONITORING FROM INTERNAL OUTFALLS 002 & 003
Facility:	GLOBAL PETROLEUM CORP - REVERE		
Facility Location:	140 LEE BURBANK HIGHWAY REVERE, MA 02151		

Report Dates & Status			
Monitoring Period:	From 12/01/21 to 12/31/21	DMR Due Date:	01/15/22
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	Tom	Title:	VP Env. H and S
Last Name:	Keefe	Telephone:	781-398-4132

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00056	Flow rate	1 - Effluent Gross	0	--	Sample	=	190.0		78 - gal/min								0	WH/DS - When Discharging	ES - ESTIMA
					Permit Req.	<=	880.0 DAILY MX		78 - gal/min										
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.74				=	7.74		12 - SU		0	01/30 - Monthly	GR - GRAB	
					Permit Req.	>=	6.5 MINIMUM			<=	8.5 MAXIMUM		12 - SU						
					Value NODI														
00556	Oil & Grease	1 - Effluent Gross	0	--	Sample	=	0.0		19 - mg/L		=	0.0		19 - mg/L		0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=	15.0 DAILY MX		19 - mg/L										
					Value NODI														
34030	Benzene	1 - Effluent Gross	0	--	Sample	=	0.0		28 - ug/L		=	0.0		28 - ug/L		0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=	51.0 MO AVG		Req Mon DAILY MX		28 - ug/L								
					Value NODI														
34247	Benzo[a]pyrene	1 - Effluent Gross	0	--	Sample	=	0.0		28 - ug/L		=	0.0		28 - ug/L		0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=	0.1 MO AVG		Req Mon DAILY MX		28 - ug/L								
					Value NODI														
34696	Naphthalene	1 - Effluent Gross	0	--	Sample	=	0.0		28 - ug/L		=	0.0		28 - ug/L		0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=	100.0 MO AVG		Req Mon DAILY MX		28 - ug/L								
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample	=	0.6		80 - Mgal/mo							0	WH/DS - When Discharging	MT - METER	
					Permit Req.		Req Mon DAILY MX		80 - Mgal/mo										
					Value NODI														
84165	Discharge event observation [Visual Monitoring]	1 - Effluent Gross	0	--	Sample						=	9.0		93 - occur/mo		0	WH/DS - When Discharging	OC - OCCURS	
					Permit Req.						Req Mon MO TOTAL		93 - occur/mo						
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
Outfall 001 data consists of data collected at Outfall 002 as a commingled discharge from Outfall 002 and Outfall 003. Discharge from Outfall 003 did not occur at the time of sampling. The data from GP-002 is, therefore, representative of the discharge at Outfall 001.

Name	Type	Size
MA0003425-002_Lab(2)_2021_12.pdf	pdf	624403.0
MA0003425-002_Lab(1)_2021_12.pdf	pdf	873487.0

Report Last Saved By
GLOBAL COMPANIES LLC
User: SBARRIENTOS@ROUXINC.COM

Name: Sara Barrientos
E-Mail: sbarrientos@rouxinc.com
Date/Time: 2022-01-13 12:37 (Time Zone: -05:00)

Report Last Signed By

User: SCHARRON@GLOBALP.COM
Name: Steven Charron
E-Mail: scharron@globalp.com
Date/Time: 2022-01-13 12:46 (Time Zone: -05:00)

DMR Copy of Record

Permit			
Permit #:	MA0003425	Permittee:	GLOBAL COMPANIES LLC
Major:	No	Permittee Address:	800 SOUTH STREET SUITE 500 WALTHAM, MA 02454
Permitted Feature:	002 External Outfall	Discharge:	002-A TREATED H2O THROUGH INTERNAL WASTE STREAM VIA OUTFALL 001
Facility:	GLOBAL PETROLEUM CORP - REVERE		
Facility Location:	140 LEE BURBANK HIGHWAY REVERE, MA 02151		

Report Dates & Status			
Monitoring Period:	From 12/01/21 to 12/31/21	DMR Due Date:	01/15/22
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	Tom	Title:	VP Env. H and S
Last Name:	Keefe	Telephone:	781-398-4132

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading				Quality or Concentration				# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2				Value 2	Qualifier 3
00056	Flow rate	1 - Effluent Gross	0	--	Sample	=	160.0		78 - gal/min						0	WH/DS - When Discharging	ES - ESTIMA
					Permit Req.	<=	830.0 DAILY MX		78 - gal/min								
					Value NODI												
00400	pH	1 - Effluent Gross	0	--	Sample	=			7.74		=	7.74	12 - SU	0	01/30 - Monthly	GR - GRAB	
					Permit Req.	>=			6.5 MINIMUM		<=	8.5 MAXIMUM	12 - SU				
					Value NODI												
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=			10.315		=	12.3	19 - mg/L	0	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	<=			30.0 MO AVG		<=	100.0 DAILY MX	19 - mg/L				
					Value NODI												
22417	Methyl tert-butyl ether [MTBE]	1 - Effluent Gross	0	--	Sample	=			0.0		=	0.0	28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=					<=	70.0 DAILY MX	28 - ug/L				
					Value NODI												
34030	Benzene	1 - Effluent Gross	0	--	Sample	=			0.0		=	0.0	28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=					<=	5.0 DAILY MX	28 - ug/L				
					Value NODI												
34696	Naphthalene	1 - Effluent Gross	0	--	Sample	=			0.0		=	0.0	28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=					<=	20.0 DAILY MX	28 - ug/L				
					Value NODI												
49491	BTEX	1 - Effluent Gross	0	--	Sample	=			0.0		=	0.0	28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=					<=	100.0 DAILY MX	28 - ug/L				
					Value NODI												
77004	Ethanol	1 - Effluent Gross	0	--	Sample	=			0.0		=	0.0	19 - mg/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.							Req Mon DAILY MX	19 - mg/L				
					Value NODI												
82181	Hydrocarbons, total petroleum	1 - Effluent Gross	0	--	Sample	=			0.0		=	0.0	19 - mg/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=					<=	5.0 DAILY MX	19 - mg/L				
					Value NODI												
82220	Flow, total	1 - Effluent Gross	0	--	Sample	=	0.6		80 - Mgal/mo					0	WH/DS - When Discharging	MT - METER	
					Permit Req.				Req Mon DAILY MX	80 - Mgal/mo							
					Value NODI												

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
------	------	------

MA0003425-002_Lab(1)_2021_12.pdf	pdf	879957.0
MA0003425-002_Lab(2)_2021_12.pdf	pdf	624403.0

Report Last Saved By

GLOBAL COMPANIES LLC

User: BRADLEY1.CONNOR
Name: Connor Bradley
E-Mail: cbradley@rouxinc.com
Date/Time: 2022-01-07 11:44 (Time Zone: -05:00)

Report Last Signed By

User: SCHARRON@GLOBALP.COM
Name: Steven Charron
E-Mail: scharron@globalp.com
Date/Time: 2022-01-13 12:46 (Time Zone: -05:00)

DMR Copy of Record

Permit			
Permit #:	MA0003425	Permittee:	GLOBAL COMPANIES LLC
Major:	No	Permittee Address:	800 SOUTH STREET SUITE 500 WALTHAM, MA 02454
Permitted Feature:	003 External Outfall	Discharge:	003-A TREATED H2O THROUGH INTERNAL WASTE STREAM VIA OUTFALL 001
Facility:	GLOBAL PETROLEUM CORP - REVERE		
Facility Location:	140 LEE BURBANK HIGHWAY REVERE, MA 02151		

Report Dates & Status			
Monitoring Period:	From 12/01/21 to 12/31/21	DMR Due Date:	01/15/22
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	Tom	Title:	VP Env. H and S
Last Name:	Keefe	Telephone:	781-398-4132

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading				Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00056	Flow rate	1 - Effluent Gross	0	--	Sample	=	30.0		78 - gal/min								0	WH/DS - When Discharging	ES - ESTIMA
					Permit Req.	<=	50.0 DAILY MX		78 - gal/min										
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.61					=	7.61		12 - SU	0	01/30 - Monthly	GR - GRAB	
					Permit Req.	>=	6.5 MINIMUM				<=	8.5 MAXIMUM		12 - SU					
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2.33					=	2.33		19 - mg/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.	<=	30.0 MO AVG				<=	100.0 DAILY MX		19 - mg/L					
					Value NODI														
22417	Methyl tert-butyl ether [MTBE]	1 - Effluent Gross	0	--	Sample							=	0.0		28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	20.0 DAILY MX		28 - ug/L					
					Value NODI														
22456	Polynuclear Aromatic Hydrocarbons [PAHs]	1 - Effluent Gross	0	--	Sample							=	0.0		28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	0.1 DAILY MX		28 - ug/L					
					Value NODI														
22456	Polynuclear Aromatic Hydrocarbons [PAHs]	EG - Effluent Gross	0	--	Sample							=	0.0		28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	10.0 DAILY MX		28 - ug/L					
					Value NODI														
22456	Polynuclear Aromatic Hydrocarbons [PAHs]	Y - Effluent Gross (Supplementary)	0	--	Sample							=	0.0		28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	100.0 DAILY MX		28 - ug/L					
					Value NODI														
34030	Benzene	1 - Effluent Gross	0	--	Sample							=	0.0		28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	5.0 DAILY MX		28 - ug/L					
					Value NODI														
34696	Naphthalene	1 - Effluent Gross	0	--	Sample							=	0.0		28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	20.0 DAILY MX		28 - ug/L					
					Value NODI														
49491	BTEX	1 - Effluent Gross	0	--	Sample							=	0.0		28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	100.0 DAILY MX		28 - ug/L					
					Value NODI														
82181	Hydrocarbons, total petroleum	1 - Effluent Gross	0	--	Sample							=	0.0		19 - mg/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	5.0 DAILY MX		19 - mg/L					
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample	=	0.012		80 - Mgal/mo							0	WH/DS - When Discharging	MT - METER	
					Permit Req.				Req Mon DAILY MX	80 - Mgal/mo									
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
MA0003425-003_Lab(1)_2021_12.pdf	pdf	828666.0

Report Last Saved By

GLOBAL COMPANIES LLC

User: SBARRIENTOS@ROUXINC.COM
Name: Sara Barrientos
E-Mail: sbarrientos@rouxinc.com
Date/Time: 2022-01-13 12:36 (Time Zone: -05:00)

Report Last Signed By

User: SCHARRON@GLOBALP.COM
Name: Steven Charron
E-Mail: scharron@globalp.com
Date/Time: 2022-01-13 12:46 (Time Zone: -05:00)

DMR Copy of Record

Permit			
Permit #:	MA0003298	Permittee:	GLOBAL COMPANIES, LLC
Major:	No	Permittee Address:	800 South Streete Suite 500 Waltham, MA 02454
Permitted Feature:	001 External Outfall	Discharge:	001-A TREATED & UNTREATED STORMWATER OUTFALL 001
Facility:	GLOBAL REVCO TERMINAL, LLC		Facility Location:
		186 LEE BURBANK HIGHWAY REVERE, MA 02151	

Report Dates & Status			
Monitoring Period:	From 12/01/21 to 12/31/21	DMR Due Date:	01/15/22
Status:	NetDMR Validated		

Considerations for Form Completion
U

Principal Executive Officer			
First Name:	Tom	Title:	VP Env. H and S
Last Name:	Keefe	Telephone:	781-398-4132

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading				Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00056	Flow rate	R - See Comments	0	--	Sample		=	35.0	78 - gal/min								0	WH/DS - When Discharging WH/DS - When Discharging	ES - ESTIMA ES - ESTIMA
					Permit Req.		<=	75.0 DAILY MX	78 - gal/min										
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample		=	7.38				=	7.38	12 - SU	0	01/30 - Monthly 01/30 - Monthly	GR - GRAB GR - GRAB		
					Permit Req.		>=	6.5 MINIMUM			<=	8.5 MAXIMUM	12 - SU						
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample		=	19.165			=	34.0	19 - mg/L	0	02/30 - Twice Per Month 02/30 - Twice Per Month	GR - GRAB GR - GRAB			
					Permit Req.		<=	30.0 MO AVG		<=	100.0 DAILY MX	19 - mg/L							
					Value NODI														
03582	Oil and grease	1 - Effluent Gross	0	--	Sample		=	0.0			=	0.0	19 - mg/L	0	01/30 - Monthly 01/30 - Monthly	GR - GRAB GR - GRAB			
					Permit Req.		<=	15.0 DAILY MX											
					Value NODI														
34030	Benzene	1 - Effluent Gross	0	--	Sample		=	0.0			=	0.0	28 - ug/L	0	01/30 - Monthly 01/30 - Monthly	GR - GRAB GR - GRAB			
					Permit Req.		<=	51.0 MO AVG			Req Mon DAILY MX	28 - ug/L							
					Value NODI														
34247	Benzo[a]pyrene	1 - Effluent Gross	0	--	Sample		=	0.061			=	0.123	28 - ug/L	0	02/30 - Twice Per Month 01/30 - Monthly	GR - GRAB GR - GRAB			
					Permit Req.		<=	0.1 MO AVG			Req Mon DAILY MX	28 - ug/L							
					Value NODI														
34696	Naphthalene	1 - Effluent Gross	0	--	Sample		=	0.0			=	0.0	28 - ug/L	0	01/30 - Monthly 01/30 - Monthly	GR - GRAB GR - GRAB			
					Permit Req.		<=	100.0 MO AVG			Req Mon DAILY MX	28 - ug/L							
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	0.124	80 - Mgal/mo					0	WH/DS - When Discharging WH/DS - When Discharging	MT - METER MT - METER			
					Permit Req.			Req Mon DAILY MX	80 - Mgal/mo										
					Value NODI														
84165	Discharge event observation [Visual Monitoring]	1 - Effluent Gross	0	--	Sample		=	26.0	93 - occur/mo					0	WH/DS - When Discharging WH/DS - When Discharging	OC - OCCURS OC - OCCURS			
					Permit Req.			Req Mon DAILY MX	93 - occur/mo										
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments		
Name	Type	Size
MA0003298-001_Lab(2)_2021_12.pdf	pdf	666207.0
MA0003298-001_Lab(1)_2021_12.pdf	pdf	875388.0

Report Last Saved By

GLOBAL COMPANIES, LLC

User: thenderson@rouxinc.com
Name: Thomas Henderson
E-Mail: thenderson@rouxinc.com
Date/Time: 2022-01-12 11:09 (Time Zone: -05:00)

Report Last Signed By

User: SCHARRON@GLOBALP.COM
Name: Steven Charron
E-Mail: scharron@globalp.com
Date/Time: 2022-01-13 13:10 (Time Zone: -05:00)

DMR Copy of Record

Permit			
Permit #:	MA0003298	Permittee:	GLOBAL COMPANIES, LLC
Major:	No	Permittee Address:	800 South Streete Suite 500 Waltham, MA 02454
Permitted Feature:	005 External Outfall	Discharge:	005-A TREATED STORMWATER & HYDROSTATIC TEST WATER OUTFALL 005
Facility:	GLOBAL REVCO TERMINAL, LLC		
Facility Location:	186 LEE BURBANK HIGHWAY REVERE, MA 02151		

Report Dates & Status			
Monitoring Period:	From 12/01/21 to 12/31/21	DMR Due Date:	01/15/22
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	Tom	Title:	VP Env. H and S
Last Name:	Keefe	Telephone:	781-398-4132

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading				Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00056	Flow rate	R - See Comments	0	--	Sample	=	350.0	78 - gal/min									0	WH/DS - When Discharging	ES - ESTIMA
					Permit Req.	<=	500.0 DAILY MX	78 - gal/min								WH/DS - When Discharging		ES - ESTIMA	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	8.16				=	8.16	12 - SU			0	01/30 - Monthly	GR - GRAB	
					Permit Req.	>=	6.5 MINIMUM			<=	8.5 MAXIMUM	12 - SU			01/30 - Monthly		GR - GRAB		
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	3.335			=	4.0	19 - mg/L			0	02/30 - Twice Per Month	GR - GRAB		
					Permit Req.	<=	30.0 MO AVG			<=	100.0 DAILY MX	19 - mg/L				02/30 - Twice Per Month	GR - GRAB		
					Value NODI														
03582	Oil and grease	1 - Effluent Gross	0	--	Sample	=	0.0			=	0.0	28 - ug/L			0	02/30 - Twice Per Month	GR - GRAB		
					Permit Req.	<=	5.0 DAILY MX			<=	5.0 DAILY MX	28 - ug/L				02/30 - Twice Per Month	GR - GRAB		
					Value NODI														
34030	Benzene	1 - Effluent Gross	0	--	Sample	=	0.0			=	0.0	28 - ug/L			0	01/30 - Monthly	GR - GRAB		
					Permit Req.	<=	2.0 DAILY MX			<=	2.0 DAILY MX	28 - ug/L				01/30 - Monthly	GR - GRAB		
					Value NODI														
34247	Benzo[a]pyrene	1 - Effluent Gross	0	--	Sample	=	0.0			=	0.0	28 - ug/L			0	01/30 - Monthly	GR - GRAB		
					Permit Req.	<=	0.1 DAILY MX			<=	0.1 DAILY MX	28 - ug/L				01/30 - Monthly	GR - GRAB		
					Value NODI														
34696	Naphthalene	1 - Effluent Gross	0	--	Sample	=	0.0			=	0.0	28 - ug/L			0	01/30 - Monthly	GR - GRAB		
					Permit Req.	<=	5.0 DAILY MX			<=	5.0 DAILY MX	28 - ug/L				01/30 - Monthly	GR - GRAB		
					Value NODI														
82220	Flow, total	1 - Effluent Gross	0	--	Sample	=	0.004	80 - Mgal/mo							0	WH/DS - When Discharging	MT - METER		
					Permit Req.		Req Mon DAILY MX	80 - Mgal/mo									WH/DS - When Discharging	MT - METER	
					Value NODI														
84165	Discharge event observation [Visual Monitoring]	1 - Effluent Gross	0	--	Sample	=	20.0	93 - occur/mo							0	WH/DS - When Discharging	OC - OCCURS		
					Permit Req.		Req Mon DAILY MX	93 - occur/mo									WH/DS - When Discharging	OC - OCCURS	
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
MA0003298-005_Lab(1)_2021_12.pdf	pdf	876775.0
MA0003298-005_Lab(2)_2021_12.pdf	pdf	667793.0

Report Last Saved By

GLOBAL COMPANIES, LLC

User: BRADLEY1.CONNOR
Name: Connor Bradley
E-Mail: cbradley@rouxinc.com
Date/Time: 2022-01-07 11:37 (Time Zone: -05:00)

Report Last Signed By

User: SCHARRON@GLOBALP.COM
Name: Steven Charron
E-Mail: scharron@globalp.com
Date/Time: 2022-01-13 13:10 (Time Zone: -05:00)

DMR Copy of Record

Permit			
Permit #:	MA0000825	Permittee:	GLOBAL COMPANIES LLC
Major:	No	Permittee Address:	800 SOUTH STREET SUITE 500 WALTHAM, MA 02454
Permitted Feature:	001 External Outfall	Discharge:	001-A TREATED STORMWATERY & HYDROSTATIC TEST WATER FROM OUTFALL 001
Facility:	GLOBAL SOUTH TERMINAL		Facility Location:
		96 LEE BURBANK HIGHWAY REVERE, MA 02150	

Report Dates & Status			
Monitoring Period:	From 12/01/21 to 12/31/21	DMR Due Date:	01/15/22
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	Tom	Title:	VP Env. H and S
Last Name:	Keefe	Telephone:	781-398-4132

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading				Quality or Concentration				# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2				Value 2	Qualifier 3
00056	Flow rate	R - See Comments	0	--	Sample		=	310.0	78 - gal/min						0	WH/DS - When Discharging	ES - ESTIMA
					Permit Req.		<=	700.0 DAILY MX	78 - gal/min								
					Value NODI												
00400	pH	1 - Effluent Gross	0	--	Sample		=	8.13			=	8.13	12 - SU	0	01/30 - Monthly	GR - GRAB	
					Permit Req.		>=	6.5 MINIMUM			<=	8.5 MAXIMUM	12 - SU				
					Value NODI												
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample		=	5.83			=	6.0	19 - mg/L	0	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.		<=	30.0 MO AVG			<=	100.0 DAILY MX	19 - mg/L				
					Value NODI												
03582	Oil and grease	1 - Effluent Gross	0	--	Sample		=	0.0			=	0.0	19 - mg/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.		<=	15.0 DAILY MX			<=	15.0 DAILY MX	19 - mg/L				
					Value NODI												
34030	Benzene	1 - Effluent Gross	0	--	Sample		=	0.0			=	0.0	28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.		<=	51.0 MO AVG			<=	15.0 DAILY MX	19 - mg/L				
					Value NODI												
34247	Benzo[a]pyrene	1 - Effluent Gross	0	--	Sample		=	0.0			=	0.0	28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.		<=	0.1 MO AVG			<=	15.0 DAILY MX	19 - mg/L				
					Value NODI												
34696	Naphthalene	1 - Effluent Gross	0	--	Sample		=	0.0			=	0.0	28 - ug/L	0	01/30 - Monthly	GR - GRAB	
					Permit Req.		<=	100.0 MO AVG			<=	15.0 DAILY MX	19 - mg/L				
					Value NODI												
82220	Flow, total	1 - Effluent Gross	0	--	Sample		=	0.002	80 - Mgal/mo					0	WH/DS - When Discharging	MT - METER	
					Permit Req.			Req Mon DAILY MX	80 - Mgal/mo								
					Value NODI												
84165	Discharge event observation [Visual Monitoring]	1 - Effluent Gross	0	--	Sample		=				=	16.0	93 - occur/mo	0	WH/DS - When Discharging	OC - OCCURS	
					Permit Req.						<=	15.0 DAILY MX	19 - mg/L				
					Value NODI												

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments		
Name	Type	Size
MA0000825_Lab(1)_2021_12.pdf	pdf	873603.0
MA0000825_Lab(2)_2021_12.pdf	pdf	664753.0

Report Last Saved By

GLOBAL COMPANIES LLC

User: BRADLEY1.CONNOR
Name: Connor Bradley
E-Mail: cbradley@rouxinc.com
Date/Time: 2022-01-07 11:24 (Time Zone: -05:00)

Report Last Signed By

User: SCHARRON@GLOBALP.COM
Name: Steven Charron
E-Mail: scharron@globalp.com
Date/Time: 2022-01-13 08:40 (Time Zone: -05:00)